

# CGSCOPS Datasheet

Carbon Monoxide ParkSafe Detector

ParkSafe

Power

Fault

Alarm




Installation

### **Product Overview**

The CGS PS range of detectors work in combination with the CGS ParkSafe, a Gas Detection & Ventilation Controller specifically designed for Parking Garage CO & NO2 monitoring. The CGSCO2PS features a electrochemical sensor for industrial and commercial indoor applications. Compact, modern, digital design makes the units aesthetically pleasing and easy to install.

#### **Popular Applications**



Chain Termination Resistor Used to select the first and last device in the chain

& Annual Service Notifications to ParkSafe Controller

## **Technical Specification**

General								
Model:		ParkSafe I	ParkSafe Detector					
Gases:		Carbon M	Carbon Monoxide					
Size: (H x W x D)		4.92 x 3.15	4.92 x 3.15 x 1.38"					
Housing Material:		ABS	ABS					
Mounting:		Wall Moun	Wall Mounting – No limits - Non-Hazardous Areas					
Weight:		1.6oz	1.6oz					
User Interface								
Display:		LED	LED					
Visual Indicators:		Power / Al	Power / Alarm / Fault					
Audible Alarm:		None	None					
Power Supply								
Power Consumpt	tion:	15mA Max	15mA Max @ 24Vdc					
DC Power:		12-32Vdc	12-32Vdc (24vdc Nominal)					
Internal Fuse:		N/A	N/A					
Equipment								
Pollution Degree:	:	2	2					
Equipment Class	:	2	2					
Environmental								
Ingress Protectio	n:		Not Formally Evaluated					
Operating:			-10 ~ 50°C / 14 ~ 122°F 30 ~ 80% RH (non-condensing)					
Storage:		-25 ~ 50°C	-25 ~ 50°C / -13~122F° up to 95% RH (non-condensing)					
Altitude Rating:		2000m	2000m					
Wiring								
Typical			Copper 18AWG (0.75mm2) Min.					
		8x screw t	8x screw terminals.					
Other								
Communication		RS485 MC	RS485 MODBUS RTU					
Sensor Specifica	tion							
Factory Calibration Conditions 25		25° ± 5°C - 77	5° ± 5°C - 77° ± 41°F (40-70% RH)					
Sensor Type El		Electromechar	lectromechanical					
Gas Sensor	Measuring Range (ppm)	Calibration Gas	Response (T90)	Recovery (T10)	Alarm: 1 (Pre alarm warning)	Alarm: 2	*EOL (Years)	
Carbon Monoxide (CO)	0-1000ppm	120ppm CO	<60s	<50s	▲25ppm	▲100ppm	5	



#### Area of coverage

Consider the coverage required and function of the area. Emphasis should be placed on airflow patterns and correct placement, not perceived detecting ranges.

The CGSCO2PS monitor should be approximately 4-5ft from the ground level.

#### Find out more Canadian Gas Safety Inc

www.canadiangassafety.com

Head office: 150 King Street West Suite 200, Toronto, ON M5H 1J9 Tel: (647) 577-1500 Email: info@canadiangassafety.com

