



### GAS ONLY






### GAS WITH ELECTRIC OFF IN ALARM





 UNLESS NOTED OTHERWISE, P.C. TO SUPPLY CONTROLLER, REMOTE SHUT-OFF BUTTONS, GAS DETECTOR AND SOLENOID AS A WHOLE SYSTEM. P.C. TO COORORDINATE WITH E.C. UNLESS NOTED OTHERWISE, WIRING, ELECTRICAL CONNECTIONS AND TESTING BY DIV 26. COORDINATE GAS SOLENOID VALVE LOCATION AND FIELD WIRING WITH DIV. 22. BASIS OF DESIGN CGS MERLIN 1000S UTILITY CONTROL SYSTEM. CONTACT CANADIAN GAS SAFETY FOR INFORMATION. WWW.CANADIANGASSAFETY.COM TEL: (647) 577 1500


# DOUBLE UP GAS PRESSURE TRANSDUCER




- VERIFY LOCATIONS OF CONTROLLER, REMOTE SHUT-OFF BUTTONS AND SOLENOID WITH DRAWINGS AND OWNER IN FIELD.
- UNLESS NOTED OTHERWISE, P.C. TO SUPPLY CONTROLLER, REMOTE SHUT-OFF BUTTONS, GAS DETECTOR AND SOLENOID AS A WHOLE SYSTEM. P.C. TO COORORDINATE WITH E.C.
- UNLESS NOTED OTHERWISE, WIRING, ELECTRICAL CONNECTIONS AND TESTING BY DIV.
   COORDINATE GAS SOLENOID VALVE LOCATION AND FIELD WIRING WITH DIV. 22. 5. PRESSURE TRANSDUCER SUPPLIED WITH CONTROL PANEL, INSTALLED IN DOWNSTREAM PORT OF GAS SOLENOID SUPPLIED BY P.C. SEE MANUFACTURER'S DETAILS.
- 120V AC SUPPLY TO CONTROLLER. 120V AC SUPPLY FROM CONTROLLER TO SOLENOID.
  LOW VOLTAGE SUPPLY SIGNAL TO PRESSURE TRANSDUCER. 12V DC SUPPLY FROM
  CONTROLLER TO GAS DETECTOR.


BASIS OF DESIGN CGS MERLIN 1000S UTILITY CONTROL SYSTEM. CONTACT CANADIAN GAS SAFETY FOR INFORMATION. WWW.CANADIANGASSAFETY.COM TEL: (647) 577 1500

### INSTALL EXAMPLE



#### GAS WITH EXHAUST FAN IN PANIC






- THICLA SEQUENCE OF DREATION MEY LOCK AUTHORITY REQUIRED TO OPEN CAS SOLEHOLD, CONTING PANEL TO PERFORM PRESSURE ORDOP TEST BEFORE ALLOWING OA INTO CLASSROOM, IN EMBAGENCY PAINC BUTTON WILL CLOSE ALL CIRCUITS, PANIC ALAMO NO 6AS DETECTION WILL INITIATE PARKE EVALUATE TAIL.
   WEIST LOCATIONS OF CONTROLLER, REMOTE SHIPT-OFF BUTTONS, RELAYS AND SOLEHOLD WITH DRAWINGS AND OWNER IN FIELD. UNLESS NOTED OTHERWISE, P.C. TO SUPPLY CONTROLLER, REMOTE SHUT-OFF BUTTONS,
  GAS DETECTOR, RELAYS AND SOLENOID AS A WHOLE SYSTEM. P.C. TO COORORDINATE
  WITH 6.7

  W
- UNLESS NOTED OTHERWISE, WIRING, ELECTRICAL CONNECTIONS AND TESTING BY DIV. 26. COORDINATE GAS SOLENOID VALVE LOCATION AND FIELD WIRING WITH DIV. 22. 6. 120V AC SUPPLY TO CONTROLLER. 120V AC SUPPLY FROM CONTROLLER TO SOLENOID. LOW VOLTAGE SUPPLY SIGNAL TO PRESSURE TRANSDUCER. 12V DC SUPPLY FROM CONTROLLER TO GAS DETECTOR. BASIS OF DESIGN CGS MERLIN 1000S UTILITY CONTROL SYSTEM. CONTACT CANADIAN GAS SAFETY FOR INFORMATION. WWW.CANADIANGASSAFETY.COM TEL: (647) 577 1500

## GAS WITH MANUAL EXHAUST FAN AND IN PANIC



BASIS OF DESIGN CGS MERLIN 1000S UTILITY CONTROL SYSTEM, CONTACT CANADIAN GAS SAFETY FOR INFORMATION. WWW.CANADIANGASSAFETY.COM TEL: (647) 577 1500

- PRESENTE TABLE MARKE MODIFIED BY ANGEL 2249-1840.

  P.C. TO PROVIDE EIGLATION
  VALVE AND UNIDOS AS REQUIRED

  GAS LINE IN

  GAS LINE IN

  GAS LINE ON

  PRESENTE TRANSLE MODIFIED BY

  TO MERLIN PANEL

  JAMES TANCE

  TO MERLIN FLUSH MOUNT WITH GSFMK BRACKET AND TRIM KIT FOR BOTH FRAMED WALLS AND BLOCK WALLS 2) DETAIL - SCIENCE CLASSROOM GAS CONTROL DIAGRAM
- VERIFY LOCATIONS OF CONTROLLER, REMOTE SHUT-OFF BUTTONS, RELAYS AND SOLENOID WITH DRAWINGS AND OWNER IN FIELD.
- UNLESS NOTED OTHERWISE, P.C. TO SUPPLY CONTROLLER, REMOTE SHUT-OFF BUTTONS, GAS DETECTOR, RELAYS AND SOLENOID AS A WHOLE SYSTEM. P.C. TO COORORDINATE WITH 6.7 UNLESS NOTED OTHERWISE, WIRING, ELECTRICAL CONNECTIONS AND TESTING BY DIV. 26. COORDINATE GAS SOLENOID VALVE LOCATION AND FIELD WIRING WITH DIV. 22. 5. PRESSURE TRANSDUCER SUPPLIED WITH CONTROL PANEL, INSTALLED IN DOWNSTREAM PORT OF GAS SOLENOID SUPPLIED BY P.C. SEE MANUFACTURER'S DETAILS. 120V AC SUPPLY TO CONTROLLER. 120V AC SUPPLY FROM CONTROLLER TO SOLENOID. LOW VOLTAGE SUPPLY SIGNAL TO PRESSURE TRANSDUCER. 12V DC SUPPLY FROM CONTROLLER TO GAS DETECTOR.
- FIRE ALARM CONTROL MODULE OUTPUT INTERRUPTS EMERGENCY SHUTOFF (EPO)
  BUTTON CIRCUIT. BASIS OF DESIGN CGS MERLIN 1000S UTILITY CONTROL SYSTEM. CONTACT CANADIAN GAS SAFETY FOR INFORMATION. WWW.CANADIANGASSAFETY.COM TEL: (647) 577 1500