

MiniMerlin

ALARM SELECTION GUIDE

1. SWITCH OFF POWER!

Unscrew the four bolts of the device using an M3 socket wrench.
Carefully remove the front fascia to expose the circuit board.

2. SWITCH ON

3. PRESS TOUCH BUTTON for 3s to start warm-up.

4. PRESS & HOLD internal button during the initialization screen. The screen will display Model Selection.

BE CAREFUL OF LINE VOLTAGE CONNECTIONS

5. TAP INTERNAL BUTTON to scroll through the Code Select options.



CODE SELECT >	Selection	Explanation
	35	CO Main Alarm @ 35ppm
	50	CO Main Alarm @ 50ppm
	TWA	CO Main Alarm @ 20ppm after two (2) Hours 50ppm after one (1) Hour 100ppm after ten (10) Minutes 300ppm after one (1) Minute

6. SELECT CODE and wait for ~10 seconds.

7. SELECTION SAVED will display on screen.

8. UNIT WILL RESTART PRESS TOUCH BUTTON for 3s to start.

info@canadiangassafety.com